



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

IQTa, IQTFa, IQTMa and IQTFMa Electric Valve Actuators.

XP/II/1/CD/T4 Ta = 60°C; XP/II/1/BCD/T4 Ta = 60°C; DIP/II/1/EFG/T4 Ta = 60°C; Type 6
a = Size 125, 250, 500, 1000, or 2000.

Equipment Ratings:

The Model IQT, IQTF, IQTM, IQTFM Range of Electric Valve Actuators as Explosionproof for Class I, Division 1, Groups B, C, D: Dust-ignitionproof for Class II, Division 1, Groups E, F and G hazardous (classified) locations, indoors and outdoors Type 6.

FM Approved for:

Rotork Controls Ltd
Brassmill Lane
Bath, BA1 3JQ
England



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3615	2006
Class 3810	2005
ANSI/NEMA-250	1991

Original Project ID: 3017942

Approval Granted: October 17, 2003

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3019253	February 9, 2004		
3033030	May 6, 2008		
3033275	June 23, 2008		
3040332	August 4, 2010		

FM Approvals LLC



J.E. Marquedant
Group Manager

4 August 2010
Date