



Certificate of Compliance

Certificate: 2291170

Master Contract: 153247

Project: 2291170

Date Issued: January 13, 2011

Issued to: Rotork Controls Inc.
675 Mile Crossing Blvd
Rochester, NY 14624
USA
Attention: Tim White

The products listed below are eligible to bear the CSA Mark shown



Ron Wildish

Issued by: Ron Wildish

PRODUCTS

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non - Incendive Systems - For Hazardous Locations

Class I, Div. 1, Group A, B, C, D:

Model *PRO* BTST Bluetooth® Actuator Setting Tool; intrinsically safe, hand-held-portable, battery operated (four 1.5 V “AAA” size Duracell, Procell Type MN2400 or Eveready Energizer, Type E92 Alkaline-Manganese or Zinc-Manganese cells); Temperature Code T4; Ambient: -30°C to +50°C.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-M91 - General Requirements – Canadian Electrical Code, Part II

CAN/CSA-C22.2 No. 157-92 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations

UL 913 (7th Ed.) - Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II and III, Division I, Hazardous Locations



Supplement to Certificate of Compliance

Certificate: 2291170

Master Contract: 153247

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2291170	January 13, 2011	Model PRO BTST Bluetooth® Actuator Setting Tool; I.S. for Class I, Division 1, Groups A,B,C,D.