



Member of the FM Global Group

FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmapprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

***PRO. Actuator Setting Tool.***

IS/II/1/ABCD/T4 Ta = 50°C

***Special Conditions of Use:***

***1. Only the following batteries shall be used. Duracell Coppertop Type MN1500, Duracell Procell Type MN1500 or GP Super Alkaline Type GP15A.***

**Equipment Ratings:**

Intrinsically Safe for use in Class I, Division 1, Groups A, B, C and D; Temperature Class T4 Ta = 50°C indoor Hazardous (Classified) Locations.

**FM Approved for:**

Rotork Controls Ltd.  
Bath, Avon, BA1 3JQ, United Kingdom