

**Certificate of Conformity No.: 28716197**

**Manufacturer:** Rotork Controls, Inc.  
675 Mile Crossing Blvd.  
Rochester, NY 14624  
United States of America

**Specifications:** IEC 61508-1÷7:2010

**Product:** Pneumatic linear double acting actuator

**Type:** Series LP/D

**RESULT:**

As per the TÜV Rheinland Italia Report No. FS 28716197 Rev. 0, we declare that the product meets the below requirements:

**IEC 61508: 2010, part 1 to 7**

**Functional Safety of electrical/electronic/programmable electronic safety related systems; Type A, Low Demand Mode, HFT=0**

Model	Safety Action	$\lambda_D$ [1/h]	$\lambda_{DD(PS)}$ [1/h]	Systematic Capability
LP/FD	Stem extended	1,90E-08	1,73E-08	3
LP/FU	Stem retracted	1,91E-08	1,74E-08	3

The above values are compatible with SIL 3.

The requirements of minimum hardware fault tolerance (HFT) according to par. 11.4.3 of IEC 61511-1 have to be observed.

The product can be used up to SIL 2 without external diagnostics.


For further details, see what written in the Safety Manual.

**Expiry date: 2019-03-31**

--- End page

Location **Milan**  
Date **2016-07-08**

Diego Sirtori  
Business Stream Manager




Attachment 1 to  
 Certificate of Conformity No.: 28716197



**Manufacturer:** Rotork Controls, Inc.  
 675 Mile Crossing Blvd.  
 Rochester, NY 14624  
 United States of America

**Specifications:** IEC 61508-1÷7:2010

**Product:** Pneumatic linear double acting actuator

**Type:** Series LP/D – Model LP/FD

		Test Interval Frequency (months)				
		6	12	24	36	48
Partial Stroke frequency (months)	1	1,08E-05	1,50E-05	2,33E-05	3,16E-05	3,99E-05
	2	1,71E-05	2,12E-05	2,95E-05	3,79E-05	4,62E-05
	3	2,33E-05	2,75E-05	3,58E-05	4,41E-05	5,24E-05
	6		4,62E-05	5,45E-05	6,28E-05	7,11E-05
	9				8,15E-05	
	12			9,19E-05	1,00E-04	1,09E-04

PFD<sub>AVG</sub> values according to IEC 61508 for different values of TI and TI<sub>PS</sub>

Test Interval Frequency (months)				
6	12	24	36	48
4,20E-05	8,36E-05	1,67E-04	2,50E-04	3,33E-04

PFD<sub>AVG</sub> values according to IEC 61508 for different values of TI (no Partial Stroke Test)

NOTES:

- The above values of PFD<sub>AVG</sub> are calculated for MRT=24 h and Proof Test Coverage=100%. For other values of MRT, TI, TI<sub>PS</sub> and/or non-perfect Proof Test, the PFD<sub>AVG</sub> values must be re-calculated.
- The PFD<sub>AVG</sub> values including Partial Stroke Test are calculated considering the use of a commercial automatic Partial Stroking Test System: for further details, see the Safety Manual.

--- End page



Attachment 2 to  
 Certificate of Conformity No.: 28716197



**Manufacturer:** Rotork Controls, Inc.  
 675 Mile Crossing Blvd.  
 Rochester, NY 14624  
 United States of America

**Specifications:** IEC 61508-1÷7:2010

**Product:** Pneumatic linear double acting actuator

**Type:** Series LP/D – Model LP/FU

		Test Interval Frequency (months)				
		6	12	24	36	48
Partial Stroke frequency (months)	1	1,09E-05	1,51E-05	2,35E-05	3,19E-05	4,03E-05
	2	1,72E-05	2,14E-05	2,98E-05	3,82E-05	4,66E-05
	3	2,35E-05	2,77E-05	3,61E-05	4,45E-05	5,28E-05
	6		4,66E-05	5,49E-05	6,33E-05	7,17E-05
	9				8,22E-05	
	12			9,27E-05	1,01E-04	1,09E-04

PFD<sub>AVG</sub> values according to IEC 61508 for different values of TI and TI<sub>PS</sub>

Test Interval Frequency (months)				
6	12	24	36	48
4,24E-05	8,43E-05	1,68E-04	2,52E-04	3,36E-04

PFD<sub>AVG</sub> values according to IEC 61508 for different values of TI (no Partial Stroke Test)

NOTES:

- The above values of PFD<sub>AVG</sub> are calculated for MRT=24 h and Proof Test Coverage=100%. For other values of MRT, TI, TI<sub>PS</sub> and/or non-perfect Proof Test, the PFD<sub>AVG</sub> values must be re-calculated.
- The PFD<sub>AVG</sub> values including Partial Stroke Test are calculated considering the use of a commercial automatic Partial Stroking Test System: for further details, see the Safety Manual.

-----End certificate

