

Certificate no.

18-SIL-0010036-06-TIC

WE HEREBY CERTIFY THAT

Product description

PNEUMATIC RACK AND PINION DOUBLE ACTING

ACTUATORS

Models

SERIES GT, RCR

Rotork Controls (India) Pvt. Ltd.

Manufacturer

23/3, Thiruvallur High Road

Thirumazhisai, Chennai 600124, India

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

IEC 61508 Parts 1-7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION

SET OUT IN THE ABOVE-MENTIONED STANDARDS

Summary Report no. RC-0220-SIL-TIC-PC-0010036-18-04

Expiry date

25.04.2022

Note

This certificate is issued upon the request of the manufacturer as voluntary certification; it does not include the production surveillance.

This certificate does not allow the manufacturer to use the safety mark of TÜV INTERCERT.

Reggio Emilia, 14.02.2020



Feridoon Sergizzarea

TÜV INTERCERT Certification Body

TÜV INTERCERT S.r.I. · Group of TÜV Saarland · Via Cecati 1/1 · 42123 Reggio Emilia ITALY www.tuvintercert.it



ANNEX to Certificate no. 18-SIL-0010036-06-TIC

Туре	A
HFT	0
Safety functions	 Delivery of a full stroke (± tolerance) driven by the piston of cylinder, powered by the specified medium working pressure
Mode of operation	Low Demand Mode

Random failure rates							
Configuration	Safety function	λ _{DU} [1/h]	λ _{DD} [1/h]	λ _s [1/h]			
GT, RCR - No PST	1	4,74E-09	0,00E+00	0,00E+00			
GT, RCR - With PST	1	4,27E-10	4,32E-09	0,00E+00			

Systematic capability	3 (Route 1 _S applied)					
	Route 1 _H :	Applied	Route 2 _H :	Applied		
Architectural constraints	The product can be used in: single channel configuration: up to SIL 2 without external diagnostic tests up to SIL 3 considering external diagnostic tests double channel configuration: up to SIL 3					

Remarks:

· For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SM-GT-00-EN.

END OF CERTIFICATE

Reggio Emilia, 14.02.2020

Dipl. Ing Feridoon Sergizzarea

TÜV INTERCERT Certification Body

Page 2 of 2