



中国国家强制性产品认证证书



证书编号：2020322307001124

认证委托人名称： Rotork Controls Limited
 认证委托人地址： Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom
 生产者名称： Rotork Controls Limited
 生产者地址： Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom
 生产企业名称： Rotork Controls Limited
 生产企业地址： Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom

产品名称： 执行器
 系列、规格、型号： IQ 系列
 标 准： GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、
 GB 12476.1-2013、GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。

发证日期：2020年9月9日 有效期至：2025年9月8日

首次发证日期：2020年9月9日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准：



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322307001124

APPLICANT: Rotork Controls Limited

ADDRESS: Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom

MANUFACTURER: Rotork Controls Limited

ADDRESS: Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom

FACTORY: Rotork Controls Limited

ADDRESS: Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom

PRODUCTNAME: Electric Valve Actuators

SERIES,SPECIFICATION,MODEL: IQ range

STANDARDS: GB 3836.1-2010、 GB 3836.2-2010、 GB 3836.3-2010、
GB 12476.1-2013、 GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:September 9, 2020

Valid until: September 8, 2025

Date of original certification:September 9, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA’s website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.siflias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0000765



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



No. : 2020322307001124

Attachment

Product: Electric Valve Actuators

Model: IQ10, IQ12, IQ18, IQ19, IQ20, IQ25, IQ35, IQ40, IQ70, IQ90, IQ95, IQ91, IQS12, IQS20, IQS35, IQM10, IQM12, IQM20, IQM25, IQM35, IQD10, IQD12, IQD18, IQD20, IQD25, IQH20, IQH25, IQH35, IQH40

Ex marking: Ex d IIC T4 Gb;
Ex d e IIC T4 Gb;
Ex tD A21 IP64 T120°C

Electrical Parameter: 200 to 600 VAC, three-phase, 50 or 60 Hz
110 to 240±10% VAC, single-phase, 50 or 60 Hz
24VDC

APPROVAL: 
Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.



中国国家强制性产品认证证书



SITIiAS
Worldwide Access

证书编号: 2020322307001124

附件

产品名称: 执行器

型号规格: IQ10, IQ12, IQ18, IQ19, IQ20, IQ25, IQ35, IQ40, IQ70, IQ90, IQ95, IQ91, IQS12, IQS20, IQS35, IQM10, IQM12, IQM20, IQM25, IQM35, IQD10, IQD12, IQD18, IQD20, IQD25, IQH20, IQH25, IQH35, IQH40

防爆标志: Ex d IIC T4 Gb;
Ex d e IIC T4 Gb;
Ex tD A21 IP64 T120°C

电气参数: 三相200~600VAC, 50/60Hz
单相110~240±10%VAC, 50/60Hz
24VDC

批准:



上海仪器仪表自控系统检验测试所有限公司