



# 中国国家强制性产品认证证书



证书编号: 2021322307003911

认证委托人名称: Rotork UK Ltd  
 认证委托人地址: 9 Brown Lane West, Holbeck, Leeds, UK  
 生产者名称: Rotork UK Ltd  
 生产者地址: 9 Brown Lane West, Holbeck, Leeds, UK  
 生产企业名称: Rotork UK Ltd  
 生产企业地址: 9 Brown Lane West, Holbeck, Leeds, UK

产品名称: SI Pro 执行器  
 系列、规格、型号: SI-1  
 标 准: GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、  
 GB 3836.9-2014

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2021年4月17日      有效期至: 2026年4月16日

首次发证日期: 2021年4月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批 准:



## 上海仪器仪表自控系统检验测试所有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2021322307003911**

**APPLICANT:** Rotork UK Ltd  
**ADDRESS:** 9 Brown Lane West, Holbeck, Leeds, UK  
**MANUFACTURER:** Rotork UK Ltd  
**ADDRESS:** 9 Brown Lane West, Holbeck, Leeds, UK  
**FACTORY:** Rotork UK Ltd  
**ADDRESS:** 9 Brown Lane West, Holbeck, Leeds, UK

**PRODUCTNAME:** Electro-Hydraulic Power Unit  
**SERIES,SPECIFICATION,MODEL:** SI-1  
**STANDARDS:** GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、  
 GB 3836.9-2014

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

**Valid from:**April 17, 2021

**Valid until:** April 16, 2026

**Date of original certification:**April 17, 2021

**The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Guo AiHua



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0004767



# 中国国家强制性产品认证证书



证书编号: 2021322307003911

## 附 件

产品名称: SI Pro 执行器

型号规格: SI-1-a-b 8  
a 代表\*\*\*, 与防爆性能无关。  
b 代表\*\*\*\*, 与防爆性能无关。

防爆标志: Ex d mb IIB/II C T4 Gb  
Ex d e mb IIB/II C T4 Gb

电气参数: 24Vdc (±10%);  
115/230 Vac, 50/60 Hz 单相 (±10%);  
380-480 Vac, 50/60 Hz 三相 (±10%)。

批 准:



## 上海仪器仪表自控系统检验测试所有限公司