



Certificate of Compliance

Certificate: 2481541

Master Contract: 236433

Project: 80105688

Date Issued: December 07, 2021

Issued to: Rotork UK Ltd
9 Brown Lane West,
Holbeck
LS12 6BH
ENGLAND
Attention: Phillip Adams

The products listed below are eligible to bear the CSA Mark shown



Issued by:

Stewart Finch IEng

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Ex db eb*, IIB, T4, $-40^{\circ}\text{C} \leq \text{Ta} \leq 65^{\circ}\text{C}$

Ex db eb*, IIC, T4, $-20^{\circ}\text{C} \leq \text{Ta} \leq 65^{\circ}\text{C}$

(*“eb” added on versions with increased safety terminal enclosure option, for single Ø and DC versions only)

Electro-Hydraulic Power Unit; Series SI-2.1; rated 24 Vdc, 190 VA or 115/230Vac, 400 VA, 50/60 Hz, single phase or 380 – 480 Vac, 205 VA, 50/60 Hz, 3 phase; Encl. Type 4 and/or 6, power unit can supply a maximum hydraulic pressure of 175 foot pound per square inch.

Evaluation only covers the Electro-Hydraulic Power Unit.



Certificate: 2481541
Project: 80105688

Master Contract: 236433
Date Issued: December 07, 2021

Specific Conditions of Use (CAN/CSA-C22.2 No. 60079-0:15, clause 29.3 e)

1. The maximum constructional gap (I_c) is less than that required by Tables 2 and 3 of CAN/CSA C22.2 No 60079-1:2016 as detailed below:

Flamepath	Maximum Gap (mm)	Minimum L (mm)
Electrical Enclosure / Electrical Cover (SI-2.1)	0.15	26.2
Electrical Enclosure/Electrical Cover (SB-2)	0.15	26.2
Terminal Enclosure/ Terminal Cover (Short)	0.15	26.7
Terminal Enclosure/ Terminal Cover (Long)	0.15	26.7
Terminal Enclosure/ Terminal Cover (Short) (IIB only)	0.2	26.7
Terminal Enclosure/ Terminal Cover (Long) (IIB only)	0.2	26.7
Main Body / Terminal Bung	0.115	25.95
Motor Enclosure/ Motor Cover	0.15	27.00
Motor Flange/Enclosure	0.15	27.00
Motor Bushing / Motor Flange	-0.035	28.00
Motor Shaft / Motor Bushing	0.167 _[Note 1]	28.00

[Note 1] This is based upon a minimum gap specification 'k' of 0.05 mm in accordance with clause 8.1.2 of CAN/CSA C22.2 No 60079-1.

2. Electro-Hydraulic Power Units that are manufactured using the enclosure window material (Makrolon 6717) are only suitable for installation in areas where the risk of impact upon the viewing window is low.
3. This equipment included some external non-metallic parts, including the outer protective coating. Cleaning must only be carried out with a damp cloth.
4. Increased safety "eb" is optional and only be applied to single phase and DC versions only.
5. All cover securing screws shall be stainless steel (A4-80) to ISO 4762.
6. Any installation must ensure that any external sources of heating or cooling, when combined with the local ambient temperature does not cause the maximum or minimum operating temperature of the equipment to be exceeded. The hydraulic system connected to the Electro-Hydraulic Power Units could provide an external heat source.
7. The final installation and/or use of the Series SI-2.1 power unit is subject to acceptance and/or inspection by CSA International or the local inspection authority having jurisdiction.



Certificate: 2481541
Project: 80105688

Master Contract: 236433
Date Issued: December 07, 2021

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-M91 (R2015)	General Requirements - Canadian Electrical Code, Part II
CAN/CSA C22.2 No 60079-0:2015	Explosive atmospheres — Part 0: Equipment — General Requirements (IEC 60079-0:2011, MOD)
CAN/CSA C22.2 No 60079-1:2016	Explosive atmospheres — Part 1: Equipment protection by flameproof enclosures “d” (IEC 60079-1:2014, MOD)
CAN/CSA C22.2 No 60079-7:2016	Explosive atmospheres — Part 7: Equipment protection by increased safety “e” (IEC 60079-7:2015, MOD)
CAN/CSA-C22.2 No. 61010-1-04	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements
CAN/CSA-C22.2 No. 94.2-15	Enclosures for electrical equipment environmental considerations.

MARKINGS

Markings as indicated below and as shown in submitter’s drawings 2032178, 2032179 and 2032181 appear on a metal nameplate mechanically fasten to each power unit.

- Submitter’s Name/Tradename/Tradename
- Hazardous Location Protection Method (eg. Ex d or Ex de)
- Temperature Code
- Operating Ambient
- Model Number
- Electrical Rating
- Serial Number
- Enclosure Type
- CSA Monogram
- Warning in regards to not open the enclosure if the area is hazardous or if unit is energized.
- Reference to year of certification and certificate number, followed by “X” to indicate special condition of use

A warning stating that “Seal conduits at enclosure wall”



Supplement to Certificate of Compliance

Certificate: 2481541

Master Contract: 236433

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80105688	December 07, 2021	<p>Change the Manufacturer to: Rotork (UK) Ltd.</p> <p>Add alternate Bartec line bush (CSA approval 2227587 (LR 85562), IECEx component approval IECEx ETS 13.0045U, UL Recognized Component E225236)</p>
70199952	January 21, 2018	<p>Update to the latest standards.</p> <p>Introduction of an alternative Short Terminal Cover 46754 and 46754CH CASTING, TERMINAL COVER (Gravity Die Cast) Aluminium BS EN 1706-AC-42000-K-T6 (LM25TF) DC and single phase versions.</p> <p>Introduction of an alternative Thermal Fuse – Type SF-129R-1, Schott Japan Corporation. HPU-800.</p> <p>Drawing amendments to address changes covered by this variation along with minor editorial changes and corrections, e.g. correct supplier/manufacturer details, remove “SMP” from drawing references, update material references to a common format.</p>
70093780	March 28, 2017	<ol style="list-style-type: none">1. Increase in the ambient temperature range from +60°C to +65°C for gas group IIC.2. Modifications to the ‘k’ and ‘m’ dimensions associated with the motor shaft flamepaths.3. Introduce an alternative terminal cover (long) manufactured in LM25-TF (heat treated) - BS 1490.4. Introduction of alternative motor types for the 24 Vdc, single phase and three phase versions.5. Drawing amendment to address the above modifications, and certain other minor drawing modifications.
70008564	July 31, 2014	Change of manufacturers address
2520331	April 30, 2012	Update of report to revise critical document list.
2481541	February 16, 2012	CSA Certification of Hydraulic Power Unit, model SI-2.1 for use in hazardous locations