



Member of the FM Global Group

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

SI-2-abc-d3. Electro-Hydraulic Power Unit.

I/1/AEx de* IIB T4 Ta = 60°C; Type 4 or 6

a = Failure Mode 0, 1, 2, 3, 4 or 5.

b = Spring Return Speed 0, 1, 2 or 9.

c = Supply Voltage 0, 1, 2 or 3.

d = Control 0, 2, 3, 4, 5, 6, 7, 8 or 9.

Special Conditions of use:

**Increased Safety rating applies when the increased safety terminal facility is specified on the single phase and DC version (Supply Voltage Option 0, 1, 2) only.*

Equipment Ratings:

The SI-2 Series Electro-Hydraulic Power Unit is rated as Flameproof and Increased Safety for Class I, Zone 1, AEx de IIB T4 Ta = 60°C hazardous (classified) locations, indoors and outdoors Type 4 or 6. The Increased Safety rating applies when the increased safety terminal facility is specified on the single phase and DC versions only.

FM Approved for:

Rotork Skilmatic, a Division of Exeeco Ltd.
Bramley, Leeds LS13 4ET, UK

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
ANSI/ISA-12.00.01-2002	2002
ANSI/ISA-12.22.01-2002	2002
ANSI/ISA-12.16.01-2002	2002
Class 3810	2005
ANSI/NEMA-250	1991

Original Project ID: 3026598

Approval Granted:

May 4, 2006


Subsequent Revision Reports / Date Approval Amended

Report Number Date

Report Number

Date

FM Approvals LLC


 Robert L. Martell, Jr.
 Assistant Vice President

May 4, 2006

 Date